UNIVERSITY OF TOLEDO FACILITIES AND CONSTRUCTION
Section: Administrative Procedure Number: ADM-04

Effective Date: January 1980 Subject: Loss of Domes; ater Supply
Revised Date: May 2023

|| Facilities Officer: Le Reviewed Date: May 2023

Standard Operating Procedure
In the event of a total or partial loss of the domestic water supply, immediate steps will be taken to notify personnel and to minimize the time needed to restore domestic service to the disrupted areas.
Purpose
To provide a systematic approach to restoring of domestic water service by outlining specific procedures which are designed to enhance communication and the safety and protection of all occupants affected by a loss of domestic water service. Procedure
1. Any person experiencing either a total loss of domestic water

10.

12.

13.

The Central Control Operator on duty may have to periodically relate the status of the domestic water outage to the Building Coordinators in preparation for announcements to be made over the P.A. systems by the Telephone Operators.

The Director, Facilities Maintenance, along with the responding supervisory staff, shall evaluate the severity of the problem and take appropriate action in restoring normal domestic water service back to the area(s) affected by the outage.

The

14.

15.

16.

17.

The lawn-irrigation well, located on the south side of Dana Center, is also capable of supplying potable water on site
at 300 gallons per minute.

Tie-in connections from the alternate water supplies to the normal domestic water distribution loop or building water
mains should be connected to the closest fire hydrant to the area or building being serviced. Isolate main by closing appropriate shut-off valves.

Temporary water may be boosted to the upper floors of the Hospital via the domestic water booster pumps operated in the "hand" position or mode.

When water service is fully restored facilities will flush all systems for a minimum of 10 minutes or until all water runs clear.

Page 3 of 3